

**Reply to Query raised through Mail or in Pre-Bid Meeting
Dated 29-11-2018**

Query	Resolution
Since completion period is short thus work will be executed in late hours also, hence space for labor hutment shall be provided by the client.	Contractor shall arrange labor hutment arrangement on their own, no space will be provided within the project premises by the client
Will water and electricity charges be borne by contractor and is electrical connection available at site.	Water and electricity charges shall be borne by the contractor and electricity connection is available at site and contractor can use it on chargeable basis
In HVAC tender minimum RA bill value is given Rs. 30.0 lacs, HVAC contractor requested for payment against material also.	Payment shall only be made against RA bills as per terms and conditions mentioned in tender. No payment will be made as an advance against material
Tenderers sought clarification regarding Billing cycle.	Billing cycle shall be as per terms condition of contract and shall be followed as it is
In HVAC tender, contradictory on location for submission of tender in Section-I and Page no-15(point 4.3.3) was there and the tenderers wanted clarification on the same.	Submission of tender shall be done at—ICAI, Guru Roop Rajat, E-32, Kalpatru Shopping Centre, Jaljog Choraya, Jodhpur, Rajasthan
Tender cost shall be mentioned in the Tender	Mentioned in Tender Rs. 2000.00 + GST @ 18 % for Interior and HVAC Tenders and Rs. 1000.00 + GST @ 18 % for Lift Tender
How much percentage of GST is considered	GST will be as per Government rule
HVAC-in general terms condition test certificates has been demanded, tenderer asked whether manufacturer test certificate are sufficient or tests to be conducted through third party and if so, than who will bear the cost of testing	As per General condition of contract testing of any material by the laboratory (if required) shall be borne by the contractor.
As per Tender lift sought for 12 passengers while size of lift well given is capable for 08 passengers only. Further after 08 capacity of lift is 10 and 13 passengers. There is no lift for 12 passenger's capacity.	Lift well is design as per Lift company guideline
In tender MRL lift is given but it is not clarified that MRL with Gear or without Gear	It is Gearless MRL lift

Make of lift not mentioned	Approved Lift make – Schindler, Otis and Mitsubishi (Japan)
Method of measurement in Bill of Quantities, item no -8 given length X Height and in other following items reference of item no 8 is given. Hence the tenderer wants clarification of Method of measurement expressing that normally visible area in Plan are considered in method of measurement in case of furniture and visible area in elevation is considered in case of Partition/storage cabinets respectively	Method of measurement for furniture & Partition/storage cabinets shall be the visible area in Plan (i.e. length x Width) and in elevation (i.e. length x Height) will be considered respectively.
Detailed drawings of furniture were asked by the tenderer	Layout Drawings has already been there in Tender
Tenderer suggested to load reply on website	Done
Mr. Mayank Gupta from Blue star requested to include their company in list for HVAC work and that blue star complies all the eligibility criteria's mentioned in the Tender	Tender is finalized by Institute so now Blue star make will not be included
He further said that 02 of companies listed in tender cannot match with the specification given in tender documents	Institute has taken care of & finalized tender accordingly
Item No 30 Tender for Interior does not contain Quantity of Projector & Specification	9 Projector are required Specification: Projector: Supplying & placing of Overhead Ceiling mount Projector of approx. 2500 lumens Panasonic/Sony Makes Roller Screen for Projector: Supplying & Placing Roller Screen having approx size 2400 * 1500 mm
Out Of your 30 items you have mention basic rates in some of your items For the tender for interior work	Basic Rates are given for selected items, Selection of which will be done by Consultant. Rate will be increased or decreased as per actual Purchase Price